

## **Certificate OF Conformity**

THIS IS TO CERTIFY THAT THE PRODUCT(S) MANUFACTURED BY NETCON ENTERPRISE PVT.LTD. HAVE BEEN TESTED AND EVALUATED IN ACCORDANCE WITH THE APPLICABLE EUROPEAN UNION DIRECTIVE 2014/30/EU (ELECTROMAGNETIC COMPATIBILITY DIRECTIVE) AND THE RELEVANT HARMONIZED STANDARDS FOR CE CONFORMITY.

Manufacture Netcon Enterprise Pvt Ltd, India

**₩**NETC**N** Brand Trade Mark

Product Uninterrupted Power System (UPS)

Contact Information Info@netconenterprise.com

Product Range 50-60 KVA Online Three Phase UPS

Model NTCS3350-TY, NTCS3360-TY

## Standards and Regulations.

Reference Standards: This classification is determined through testing according to the standard EN IEC 62040-2:2018, EN 61000-3-12:2011, EN IEC 61000-3-11:2020.

EN IEC 62040-2:2018	Electromagnetic emissions and the required immunity performance of UPS equipment operating at voltages up to 1,000 V AC or 1,500 V DC, in residential, commercial, or industrial environments
EN 61000-3-12:2011	Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤75 A per phase.
IEC 61000-3- 11:2020	Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤75 A and subject to conditional connection

UPS complies with essential EU directives, including by adhering to harmonized standards like EN IEC 62040-1 (safety), EN IEC 62040-2:2018 (EMC), manufacturers ensure their UPS is safe, Reliable, and free from harmful interference.





Authorized Signatory Managing Director.

