

Certificate of Conformity

NO.: ENS2409250306E00101C

The following product has been tested by us with the listed standards and found in conformity with the council EMC directive 2014/30/EU. This is to certify that the specimen is in conformity with the assessment requirement mentioned follow. This certificate does not imply assessment to the production of the product.

Applicant : Netcon Enterprise Pvt Ltd.

Address : 430A, Kathirvedu, Puzhal, Chennai- 600066, India

Manufacturer : Shenzhen Consnant Technology Co., Ltd.

Address : Building B6, Junfeng Industrial Park, Yonghe Road, Fuhai
Sub-District, Bao'an District, Shenzhen City, 518103, P.R.China

Trade Mark : 

EUT : Outdoor UPS 6-10KVA with air conditioner

M/N : NTPR6K, NTPR10K

Test Standards : EN IEC 62040-2:2018
EN 61000-3-12:2011
EN IEC 61000-3-11:2019

Version : Ver.1.0



(Manager)

November 27, 2024

The certificate is based on a single evaluation of one sample of above-mentioned products, It does not imply an assessment of the whole production and does not permit the use of the test lab logo.

EMTEK (Shenzhen) Co., Ltd.

Add: Building 69, Majialong Industry Zone, Nanshan District, Shenzhen, Guangdong, China [Http://www.emtek.com.cn](http://www.emtek.com.cn) E-mail: cs.rep@emtek.com.cn

